

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Thu, 25 Jul 2024 09:16:48 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
ALLAN SOUTH RURAL WATER UTILITY WATERWORKS- PIPELINE	28-Sep-22	PDWA Issued to Allan South Rural Water Utility (portion only) - Due to Low Chlorine Level	1		Operational: Inadequate disinfection residual in distribution system Quality: Exceedance of MAC or drinking water standard
AVONLEA WATERWORKS	23-Jul-24	PDWA - Village of Avonlea	1		Operational: Treatment unable to cope with significant deterioration in source water quality Quality:
BLADWORTH WATERWORKS	26-Jun-24	PDWA issued - Village of Bladworth - Effective Wed June 26, 2024 at 5PM until further notice	1		Operational: Treatment / distribution equipment failure or damage Quality: Unacceptable turbidity or particle counts in treated water

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Thu, 25 Jul 2024 09:16:48 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
BOGGY CREEK WATER UTILITY CORP WATERWORKS Boggy Creek Water Utility Corp	20-Oct-16	Boggy Creek Water Utility - Does not meet minimum treatment requirements	1		Operational: Does not meet minimum treatment/design requirements Quality:
BROADVIEW WATERWORKS	26-Jul-24	PDWA issued - Broadview (portion) - effective Friday July 26 @ 9AM until further notice	1		Operational: Planned system maintenance Quality: Line break or pressure loss in distribution system
CANWOOD	19-Jul-24	PDWA - Village of Canwood - Water Line Repairs and Depressurization - Effective July 19, 2024	1		Operational: Quality: Line break or pressure loss in distribution system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Thu, 25 Jul 2024 09:16:48 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
CARIBOU SOUTH WATER USERS COOPERATIVE WATERWORKS-PIPELINE (Moose Jaw)	30-Nov-05	Caribou South Water Users Co-operative - PDWA - Inadequate Chlorine Residuals	1		Operational: Inadequate disinfection residual in distribution system Quality:
CARNDUFF WATERWORKS	24-Jul-24	PDWA issued - Carnduff (portion) effective immediately until further notice	1		Operational: Quality: Line break or pressure loss in distribution system
CARONPORT	23-Jul-24	PDWA - Town of Caronport - , effective July 23, 2024 9:00 AM	1		Operational: Planned system maintenance Quality: Line break or pressure loss in distribution system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Thu, 25 Jul 2024 09:16:48 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
CLAUDE RESOURCES - SANTOY 8 WATERWORKS	13-Jul-22	PDWA - SSR Mining Santoy WTP	1		Operational: Does not meet minimum treatment/design requirements Quality:
COTTONWOOD WATER USERS INC. WATERWORKS	30-Dec-13	PDWA Issued to the Cottonwood Water Users Inc. due to Seasonal Low Chlorine Residual	1		Operational: Inadequate disinfection residual in distribution system Quality:
CRYSTAL LAKE WATERWORKS	19-May-21	Crystal Lake PDWA (Do Not Consume) elevated arsenic	1		Operational: Quality: Exceedance of MAC or drinking water standard

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Thu, 25 Jul 2024 09:16:48 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
CSW WATER CLUB WATERWORKS	04-Dec-14	PDWA - CSW Water Club - Low Chlorine Residual	1		Operational: Inadequate disinfection residual in distribution system Quality:
DALMENY	22-Jul-24	PDWA Issued to Dalmeny (Portion) - Planned Maintenance - EFFECTIVE Monday July 22/24 at 8:30 am	1		Operational: Planned system maintenance Quality: Line break or pressure loss in distribution system
DALMENY	22-Jul-24	PDWA Issued to Dalmeny (Portion) - Water Break/Depressurization	1		Operational: Treatment / distribution equipment failure or damage Quality: Line break or pressure loss in distribution system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Thu, 25 Jul 2024 09:16:48 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
EDENWOLD WATERWORKS	22-Jul-24	Edenwold - PDWA Portion (Cayne and Eden Street	1		Operational: Treatment / distribution equipment failure or damage Quality: Line break or pressure loss in distribution system
EIGHT MILE PIPELINE ASSOCIATION WATERWORKS	07-Mar-24	PDWA - Eight Mile Pipeline - low chlorine levels	1		Operational: Inadequate disinfection residual in distribution system Quality:
ELSTOW N. RURAL WATER UTILITY WATERWORKS	17-Sep-15	PDWA - Elstow N Rural Water Utility (amended) due to inadequate chlorine level in the dist. system	1		Operational: Inadequate disinfection residual in distribution system Quality: Exceedance of MAC or drinking water standard

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Thu, 25 Jul 2024 09:16:48 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
FLAXCOMBE WATERWORKS	22-Jul-24	PDWA - Village of Flaxcombe effective immediately July 22, 2024 4:00 PM	1		Operational: Quality: Line break or pressure loss in distribution system
FLEMING WATERWORKS	12-Jul-22	PDWA Issued - Town of Fleming - Effective Immediately - July 12, 2022 - Equipment failure	1		Operational: Treatment / distribution equipment failure or damage Quality:
GLENSIDE WATERWORKS	28-Jun-23	PDWA - Village of Glenside	1		Operational: Treatment / distribution equipment failure or damage Quality: Unacceptable turbidity or particle counts in treated water

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Thu, 25 Jul 2024 09:16:48 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
GRAVELBOURG	23-Jul-24	PDWA - Town of Gravelbourg - localized - affects 4th Ave E. - Main St. to Magnan St., effective imme	1		Operational: Quality: Line break or pressure loss in distribution system
HANLEY WATERWORKS	21-Nov-17	TOWN OF HANLEY, SK - PDWA, (Portion) Inadequate disinfection levels	1		Operational: Inadequate disinfection residual in distribution system Quality:
HAWARDEN WATERWORKS	02-May-23	PDWA - Village of Hawarden	1		Operational: Does not meet monitoring requirements Quality: Significant deterioration of source water quality suspected or confirmed due to environmental conditions

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Thu, 25 Jul 2024 09:16:48 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
HAZEL DELL WATERWORKS	27-Oct-23	PDWA - Hazel Dell - Effective Immediately - Elevated Turbidity	1		Operational: Quality: Unacceptable turbidity or particle counts in treated water
HAZLET	15-Jun-21	Precautionary Drinking Water Advisory (PDWA) - Elevated Turbidity - Village of Hazlet	1		Operational: Treatment / distribution equipment failure or damage Quality: Unacceptable turbidity or particle counts in treated water
HUTTERIAN BRETHERN CHURCH OF HODGEVILLE WATERWORKS	05-Dec-23	PDWA - Hodgeville Hutterite Colony - alternative potable supply - positive coliforms	1		Operational: Treatment / distribution equipment failure or damage Quality: Total coliforms detected in drinking water system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Thu, 25 Jul 2024 09:16:48 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
HUTTERIAN BRETHREN CHURCH OF MCGEE WATERWORKS	24-Nov-22	PDWA - Do Not Consume - McGee Colony - Non NSF Chemical Use -	1		Operational: Quality: Exceedance of MAC or drinking water standard
HUTTERIAN BRETHREN CHURCH OF WEST BENCH WATERWORKS	09-May-20	West Bench Colony of Hutterian Brethren - PDWA, Due to contaminated repeat bacteria sample	1		Operational: Quality: Total coliforms detected in drinking water system
KATEPWA RV PARK LTD. WATERWORKS	21-Jul-24	PDWA - Katepwa RV Park - Effective immediately, July 21, 2024 - Water ine Break	1		Operational: Quality: Line break or pressure loss in distribution system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Thu, 25 Jul 2024 09:16:48 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
KENNEDY Village office well	14-Jun-24	PDWA village of kennedy town office well	1		Operational: Quality:
KEYSTOWN WATERWORKS	31-Jan-18	PDWA issued to Hamlet of Keystown due to inadequate disinfection residual	1		Operational: Inadequate disinfection residual in distribution system Quality:
LAC VERT WATERWORKS	25-Aug-20	Lac Vert PDWA -Turbidity Exceedance	1		Operational: Undetermined source of contamination Quality: Unacceptable turbidity or particle counts in treated water

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Thu, 25 Jul 2024 09:16:48 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
LAKESIDE WATER UTILITY PIPELINE	07-Feb-23	PDWA Issued to Lakeside Water Utility - Inadequate Chlorine levels in distribution system	1		Operational: Inadequate disinfection residual in distribution system Quality: Exceedance of MAC or drinking water standard
LEASK	24-Jul-24	Village of Leask - PDWA	1		Operational: Treatment / distribution equipment failure or damage Quality: Line break or pressure loss in distribution system
LINE 19 WATER PIPELINE UTILITY WATERWORKS	17-Apr-24	Line 19 Pipeline PDWA Lack of Disinfection	1		Operational: Inadequate disinfection residual in distribution system Quality:

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Thu, 25 Jul 2024 09:16:48 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
MARCELIN	13-Jul-24	Marcelin - PDWA	1		Operational: Treatment / distribution equipment failure or damage Quality: Line break or pressure loss in distribution system
MEACHAM WATERWORKS	17-Jul-24	PDWA - Meacham (localized) - effective immediately - water line repairs	1		Operational: Quality: Line break or pressure loss in distribution system
MELFORT WATERWORKS Residents S. of Melfort on the Arji Can extension	17-Dec-04	Melfort - South of Melfort on the Agriculture Canada extension - PDWA - Low chlorination	1		Operational: Inadequate disinfection residual in distribution system Quality: Line break or pressure loss in distribution system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Thu, 25 Jul 2024 09:16:48 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
MEOTA	24-Jul-24	Village of Meota PDWA (Isolated Area) - Issued due to line repair	1		Operational: Quality: Line break or pressure loss in distribution system
MOOSE CREEK REGIONAL PARK WATERWORKS	01-Jun-21	PDWA issued - Moose Creek Regional Park Authority	1		Operational: Treatment unable to cope with significant deterioration in source water quality Quality: Unacceptable turbidity or particle counts in treated water
MOOSOMIN	23-Jul-24	PDWA Issued - Town of Moosomin - Effective July 23, 2024@8am - Service installation	1		Operational: Planned system maintenance Quality: Line break or pressure loss in distribution system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Thu, 25 Jul 2024 09:16:48 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
NEUDORF WATERWORKS	08-Jul-24	Neudorf PDWA Main Replacement 100 and 200 Block Niedergall St	1		Operational: Planned system maintenance Quality:
NEUDORF WATERWORKS	10-Jun-24	Nuedorf - PDWA Portion	1		Operational: Planned system maintenance Quality: Line break or pressure loss in distribution system
ODESSA	10-Jun-24	Village of Odessa - PDWA Portion	1		Operational: Planned system maintenance Quality: Line break or pressure loss in distribution system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Thu, 25 Jul 2024 09:16:48 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
PADDOCKWOOD	10-Jul-24	Paddockwood(part) - PDWA	1		Operational: Planned system maintenance Quality: Line break or pressure loss in distribution system
PELLY	13-Sep-22	Pelly PDWA - elevated turbidity and inadequate chlorine residual	1		Operational: Inadequate disinfection residual in distribution system Quality: Unacceptable turbidity or particle counts in treated water
PLEASANTDALE WATERWORKS	29-Feb-24	PDWA issued - Village of Pleasantdale - Elevated Turbidity leaving the WTP	1		Operational: Treatment / distribution equipment failure or damage Quality: Unacceptable turbidity or particle counts in treated water

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Thu, 25 Jul 2024 09:16:48 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
PLUNKETT WATERWORKS	04-Jan-22	VILLAGE OF PLUNKETT, SK - PDWA, Due to no certified or adequately trained operator as required	1		Operational: No certified or adequately trained operator as required Quality:
PRELATE	10-May-21	PDWA - Village of Prelate - elevated turbidity in the distribution system	1		Operational: Treatment unable to cope with significant deterioration in source water quality Quality: Unacceptable turbidity or particle counts in treated water
PRUD'HOMME WATERWORKS	07-May-24	Village of Prue'homme PDWA - Issued due to depressurization caused by line break	1		Operational: Quality: Line break or pressure loss in distribution system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Thu, 25 Jul 2024 09:16:48 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
QU'APPELLE	10-Jul-24	Updated (PDWA) Valve Replacement Qu'Appelle Street/Hwy 35 Qu'Appelle 6th to 10th Avenue	1		Operational: Planned system maintenance Quality: Line break or pressure loss in distribution system
QU'APPELLE VALLEY WATER USERS ASSOCIATION WATERWORKS	24-Jul-24	Qu'Appelle Valley Water Users - PDWA	1		Operational: Treatment / distribution equipment failure or damage Quality: Line break or pressure loss in distribution system
QUINTON WATERWORKS	14-Jan-23	PDWA - Village of Quinton - water break and depressurization	1		Operational: Quality: Line break or pressure loss in distribution system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Thu, 25 Jul 2024 09:16:48 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
REDTHORPE UTILITY BOARD WATERWORKS	23-Jul-24	PDWA - Redthorpe Utility Board	1		Operational: Treatment unable to cope with significant deterioration in source water quality Quality:
REGINA WATERWORKS Boggy Creek Well Field - Only affects two rural customers	24-Jul-06	This PDWA is for two City customers at the Boggy Creek Well field. Only in affect when wells operate.	1		Operational: Inadequate disinfection residual in distribution system Quality:
RICHMOUND WATERWORKS	20-Jul-24	PDWA - Richmond - Effective Immediately - System Depressurization	1		Operational: Quality: Line break or pressure loss in distribution system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Thu, 25 Jul 2024 09:16:48 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
ROCANVILLE WATERWORKS	23-Jul-24	PDWA Issued - Town of Rocanville - Effective July 23, 2024@9am - Scheduled Maintenance	1		Operational: Planned system maintenance Quality:
ROSTHERN	15-Jul-24	Rosthern (Part) - PDWA	1		Operational: Planned system maintenance Quality: Line break or pressure loss in distribution system
ROSTHERN	23-Jul-24	Rosthern (100-400Railway) - PDWA	1		Operational: Planned system maintenance Quality: Line break or pressure loss in distribution system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Thu, 25 Jul 2024 09:16:48 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
ROSTHERN	18-Jul-24	Rosthern (Part) - PDWA	1		Operational: Planned system maintenance Quality: Line break or pressure loss in distribution system
SALTCOATS	23-Jul-24	PDWA Issued - Town of Saltcoats (Portion) - Effective Tuesday, July 23, 2024@10am - Valve replacemen	1		Operational: Planned system maintenance Quality:
SANDY BAY WATERWORKS	01-Jul-24	PDWA issued - Northern Village of Sandy Bay (Village Side) - effective July 1, 2024 at 2am	1		Operational: Quality: Line break or pressure loss in distribution system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Thu, 25 Jul 2024 09:16:48 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
SCEPTRE	23-Jul-24	PDWA - Sceptre	1		Operational: Power outage resulting in system pressure loss or reduced storage of treated water Quality: Line break or pressure loss in distribution system
SHEHO WATERWORKS	10-Nov-21	Sheho PDWA - inadequate disinfection residuals in the distribution system	1		Operational: Inadequate disinfection residual in distribution system Quality: Insufficient Quantity
SPC-POPLAR RIVER POWER STN WATERWORKS PDWA issued at SPC-Poplar River due to Power Outage and depressurization.	27-Oct-20	PDWA issued at SPC-Poplar River due to a Power Outage and depressurization	1		Operational: Power outage resulting in system pressure loss or reduced storage of treated water Quality: Line break or pressure loss in distribution system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Thu, 25 Jul 2024 09:16:48 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
ST. GREGOR WATERWORKS	08-Feb-23	PDWA - Village of St. Gregor (all) - Effective Immediately	1		Operational: Treatment / distribution equipment failure or damage Quality: Unacceptable turbidity or particle counts in treated water
STONY BEACH WATERWORKS	09-Dec-14	PDWA Issued to the Hamlet of Stony Beach due to Seasonal Low Chlorine Residual	1		Operational: Inadequate disinfection residual in distribution system Quality:
STURGIS	24-Jul-24	Sturgis PDWA - Elevated Turbidity due to Water Break	1		Operational: Treatment / distribution equipment failure or damage Quality: Unacceptable turbidity or particle counts in treated water

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Thu, 25 Jul 2024 09:16:48 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
SUNNYSIDE COTT.OWN. WATERWORKS	01-May-24	PDWA - Sunnyside -Startup	1		Operational: Start up of waterworks Quality: Suspected contamination
TISDALE	16-Jul-24	Tisdale PDWA (portions) - System Depressurization Due to Main Replacement om 100Th St	1		Operational: Treatment / distribution equipment failure or damage Quality: Line break or pressure loss in distribution system
TURNOR LAKE	23-Jul-24	NH of Turnor Lake PDWA - depressurization	1		Operational: Quality: Line break or pressure loss in distribution system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Thu, 25 Jul 2024 09:16:48 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
UNITY	23-Jul-24	Town of Unity PDWA (isolated area) - issued due to line repair	1		Operational: Quality: Line break or pressure loss in distribution system
URANIUM CITY WATERWORKS	11-Feb-15	Uranium City		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system
WAPPELLA WATERWORKS	25-Jul-24	PDWA Issued - Town of Wapella - Effective Immediately July 25, 2024 - Power outage and system depres	1		Operational: Power outage resulting in system pressure loss or reduced storage of treated water Quality: Line break or pressure loss in distribution system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Thu, 25 Jul 2024 09:16:48 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
WATSON	19-Jul-24	Watson PDWA (portion) - System Depressurization - Water Main Break	1		Operational: Treatment / distribution equipment failure or damage Quality: Line break or pressure loss in distribution system
WEIRDALE WATERWORKS	06-Oct-23	Precautionary Drinking Water Advisory - Village of Weirdale - Lack of Primary Disinfection	1		Operational: Inadequate disinfection residual in distribution system Quality:
WOLLASTON LAKE WATERWORKS	12-Jul-24	PDWA - Northern Settlement of Wollaston Lake	1		Operational: Power outage resulting in system pressure loss or reduced storage of treated water Quality: Insufficient Quantity

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Thu, 25 Jul 2024 09:16:48 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
WOOD RIVER UTILITY BOARD - LAKE VIEW PIPELINE	17-Jan-23	PDWA Lakeview Water Co-op	1		Operational: Planned system maintenance Quality: Line break or pressure loss in distribution system
WOOD RIVER UTILITY BOARD WATERWORKS (LAFLECHE WOODALE)	17-Jan-23	PDWA - WRUB (Woodale)	1		Operational: Planned system maintenance Quality: Line break or pressure loss in distribution system
YELLOW CREEK WATERWORKS	06-May-24	20240506 Yellow Creek PDWA High Turbidity	1		Operational: Damaged or inadequately maintained cistern or holding tank Quality: Suspected contamination

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Thu, 25 Jul 2024 09:16:48 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
ZELMA WATERWORKS	06-Apr-23	PDWA for Village of Zelma (all) - inadequate disinfection and uncertified operator	1		Operational: Inadequate disinfection residual in distribution system Quality:
ZENON PARK WATERWORKS	27-Jun-24	20240627 Zenon Park PDWA - Water Tower Maintenance	1		Operational: Planned system maintenance Quality:

Totals: 82 1