

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
2553301 Alberta Ltd (Trading as 24Seven Travel Centre) Water Supply (#F0081174)	27-Mar-24  Saskatoon Regional Health Authority	PDWA issued to 2553301 Alberta Ltd (Trading as 24Seven Travel Centre) due to unapproved alterations	1		Operational: Treatment / distribution equipment failure or damage  Quality:
50's Blacktop Diner / Olive Tree Restaurant [600625]	10-Feb-23  Saskatoon Regional Health Authority	PDWA for 50's Blacktop Diner / Olive Tree Restaurant / Riverbend Gas & Store	1		Operational: Treatment / distribution equipment failure or damage  Quality: Total coliforms detected in drinking water system
Airport Well - La Ronge [16588]	13-Feb-18  Mamawetan Churchill River Regional Health Authority	La Ronge Airport, Do Not Consume, 13Feb2018 high levels of chemical - PFOA and PFOS	1		Operational: Undetermined source of contamination  Quality: Exceedance of MAC or drinking water standard

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Angler Trail Resort Ltd. (Darsana Property) [22007]	11-Jun-09 Mamawetan Churchill River Regional Health Authority	PDWA for Angler Trail Resort Ltd. (Darsana Property) [22007]	1		Operational: Inadequate disinfection residual in distribution system  Quality: Total coliforms detected in drinking water system
Approved Home of Shirley Cox - Hauled Water [13890]  Approved Home of Shirley Cox - Hauled Water [13890]	22-Sep-16 Sunrise Regional Health Authority	PDWA - Approved Home of Shirley Cox Hauled Water [013890]	1		Operational:  Quality: Total coliforms detected in drinking water system
Arctic Lodges [15000]	19-Aug-22 Mamawetan Churchill River Regional Health Authority	PDWA Issued for Arctic Lodges, Reindeer Lake, Total Coliform Detected, Aug 19, 2022	1		Operational: Inadequate disinfection residual in distribution system  Quality: Total coliforms detected in drinking water system

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Athabasca Fishing Lodges - Engler Lake Lodge - No Bookings 2018 [15232]	01-Jul-07  Mamawetan Churchill River Regional Health Authority	EBWO for Athabasca Fishing Lodges - Engler Lake due to E.coli		1	Operational: Inadequate disinfection residual in distribution system  Quality: E.coli detected in drinking water system
Bear's Camp [1100034]  Bear's Camp [1100068]	29-Jul-16  Mamawetan Churchill River Regional Health Authority	Bear's Camp, PDWA, Total Coliforms Present	1		Operational: No or inadequate disinfection at the treatment plant  Quality: Total coliforms detected in drinking water system
Besnard Lake Campground [15994]	10-Aug-19  Mamawetan Churchill River Regional Health Authority	EBWO Besnard Lake Campground 10Aug19		1	Operational: Inadequate disinfection residual in distribution system  Quality: E.coli detected in drinking water system

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Big River Bible Camp [305]	27-Jun-19 Prince Albert Parkland Regional Health Authority	Precautionary Drinking Water Advisory-Big River Bible Camp	1		Operational: Undetermined source of contamination  Quality: Total coliforms detected in drinking water system
Black Bear Island Lodge [14691]	14-Jun-14 Mamawetan Churchill River Regional Health Authority	Black Bear Island Lodge		1	Operational: Inadequate disinfection residual in distribution system  Quality: E.coli detected in drinking water system
Bloomfield's Ballantyne Bay Resort - Surface Water Source [12364]	14-Sep-22 Mamawetan Churchill River Regional Health Authority	EBWO issued on Bloomfield's Ballantyne Bay Resort, E. coli detected, 09/14/2022		1	Operational: No or inadequate disinfection at the treatment plant  Quality: E.coli detected in drinking water system

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Buffalo Hump Community Well [13770]	19-Apr-23  Sunrise Regional Health Authority	PDWA Issued for Buffalo Hump Community Well, Total Coliform Detected, April 19, 2023	1		Operational: Contamination during construction, repair or operation  Quality: Total coliforms detected in drinking water system
Burbidge Lake Lodge Ltd. [16531]	08-Jul-14  Mamawetan Churchill River Regional Health Authority	Burbidge Lake Lodge Ltd.	1		Operational: Inadequate disinfection residual in distribution system  Quality: Total coliforms detected in drinking water system
Camp Can-Ta-Ka-Ye Well [20891]	25-May-12  Heartland Regional Health Authority	Camp Can-Ta-Ka-Ye PDWA	1		Operational: Does not meet minimum treatment/design requirements  Quality: Unacceptable turbidity or particle counts in treated water

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Camp Kinisoo (1976) Ltd. [15315]	08-Jun-12  Mamawetan Churchill River Regional Health Authority	Camp Kinisoo (1976) Ltd.	1		Operational: Inadequate disinfection residual in distribution system  Quality: Total coliforms detected in drinking water system
Camp Woodboia Well [11245]	04-May-20  Five Hills Regional Health Authority	PDWA Issued to Camp Woodboia	1		Operational: Start up of waterworks  Quality:
Cando Memorial Hall Well [24390]	09-Jul-14  Heartland Regional Health Authority	EBWO Cando Memorial Hall		1	Operational:  Quality: E.coli detected in drinking water system

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Cando School Well [15926]	10-Mar-17 Heartland Regional Health Authority	PDWA for the Cando School (Untreat portion of water system)	1		Operational: Does not meet minimum treatment/design requirements  Quality: Total coliforms detected in drinking water system
Canora Beach Resort - Main Well [17155]	04-Sep-09 Sunrise Regional Health Authority	PDWA for Canora Beach Resort Public Water Supply [17155] due to the presence of coliform bacteria	1		Operational:  Quality: Total coliforms detected in drinking water system
Cheemo Lodge [15028]	07-Jul-14 Mamawetan Churchill River Regional Health Authority	Cheemo Lodge		1	Operational: Inadequate disinfection residual in distribution system  Quality: E.coli detected in drinking water system

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Churchill River Voyageur Lodge [15570]	24-Jun-11  Mamawetan Churchill River Regional Health Authority	EBWO Churchill River Voyager Lodge - upgraded from existing PDWA		1	Operational:  Quality: E.coli detected in drinking water system
Churchill River Wilderness Camps [14673]	24-Jun-11  Mamawetan Churchill River Regional Health Authority	EBWO for Churchill River Wilderness Camp due to E.coli		1	Operational: Inadequate disinfection residual in distribution system  Quality: E.coli detected in drinking water system
Coldwell Campground Public Water Supply [17154]	21-Jun-18  Heartland Regional Health Authority	Coldwell Recreation Site Campground PDWA	1		Operational: Does not meet minimum treatment/design requirements  Quality: Total coliforms detected in drinking water system



## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Coleville Campground Water Supply [24901]	10-Jun-21  Heartland Regional Health Authority	PDWA issued on Coleville Campground Water Supply due to inadequate chlorine residual.	1		Operational: Inadequate disinfection residual in distribution system  Quality:
Country Thunder LLC Well Water Supply [14258]	07-Jul-22  Regina Qu'Appelle Regional Health Authority	PDWA - Country Thunder Well Water Supply	1		Operational: Does not meet minimum treatment/design requirements  Quality: Unacceptable turbidity or particle counts in treated water
Cree Lake Lodge [15708]	10-Aug-21  Mamawetan Churchill River Regional Health Authority	Cree Lake Lodge, PDWA 10Aug2021, Treatment Application to be finalized	1		Operational: Does not meet minimum treatment/design requirements  Quality:

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Cree River Lodge Inc. [15027]	13-Jul-17 Mamawetan Churchill River Regional Health Authority	PDWA Cree River Lodge Inc., 13jul2017, 23 Total Coliforms/100mL	1		Operational: Inadequate disinfection residual in distribution system  Quality: Total coliforms detected in drinking water system
Crystal Lodge Inc. [15361]	28-Jun-10 Mamawetan Churchill River Regional Health Authority	EBWO - Crystal Lodge Ltd. Ispatamow Island, Cree Lake - existing PDWA amended to EBWO		1	Operational:  Quality: Total coliforms detected in drinking water system
Davidson Golf & Country Club Well [20702]	29-May-19 Heartland Regional Health Authority	PDWA Issued to Davidson Golf Club Well due to Seasonal Start Up	1		Operational: Start up of waterworks  Quality:

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Drinking Falls Lodge [14696]	24-Jun-10  Mamawetan Churchill River Regional Health Authority	EBWO issued for Drinking Falls Lodge [14696]		1	Operational: No or inadequate disinfection at the treatment plant  Quality:
Duck Pond Guest House (24091)	16-Apr-14  Sunrise Regional Health Authority	EBWO Issued for Duck Pond Guest House	1		Operational: Undetermined source of contamination  Quality: E.coli detected in drinking water system
Duck Pond Guest House (24091)	16-Apr-14  Sunrise Regional Health Authority	EBWO Issued for Duck Pond Guest House	1		Operational: Undetermined source of contamination  Quality: E.coli detected in drinking water system
Dyer Straits Campground (F0016912)	05-Sep-15  Regina Qu'Appelle Regional Health Authority	PDWA - Dyer Straits Campground Well	1		Operational: Undetermined source of contamination  Quality: Total coliforms detected in drinking water system

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Elbow Lutheran Bible Camp Well [11299]	04-May-20  Five Hills Regional Health Authority	PDWA Issued to Elbow Lutheran Bible Camp	1		Operational: Start up of waterworks  Quality:
Eston Regional Park Water Supply [15595]	25-May-12  Heartland Regional Health Authority	Emergency Boil Water Order for Eston Regional Park Water System, located in Heartland Health Region		1	Operational: Does not meet minimum treatment/design requirements  Quality: E.coli detected in drinking water system
Eye Hill Creek Outfitters Well [9516]	15-Jun-15  Mamawetan Churchill River Regional Health Authority	Eyehill Creek Outfitters, EBWO, E.coli detected in drinking water system		1	Operational: Inadequate disinfection residual in distribution system  Quality: E.coli detected in drinking water system

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Eyehill Creek Outfitters (29494)	23-Jul-21 Mamawetan Churchill River Regional Health Authority	Eyehill Creek Outfitters, EBWO, E.coli present in distribution		1	Operational: Inadequate disinfection residual in distribution system  Quality: E.coli detected in drinking water system
Fishing Lake Bible Camp	28-Jun-19 Saskatoon Regional Health Authority	PDWA issued to Fishing Lake Bible Camp (6570) for high turbidity	1		Operational: Does not meet minimum treatment/design requirements  Quality: Unacceptable turbidity or particle counts in treated water
Fiske Bar and Grill PW (25938)	16-Jan-17 Heartland Regional Health Authority	PDWA Issued Due to Lack of Treatment	1		Operational: Does not meet minimum treatment/design requirements  Quality: Suspected contamination

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Flotten Lake Distribution System [12324]	17-Sep-19 Prairie North Regional Health Authority	Flotten Lake Distribution - Do Not Consume	1		Operational: Does not meet minimum treatment/design requirements  Quality: Exceedance of MAC or drinking water standard
Flotten Lake Resort Distribution System [12322]	15-Sep-13 Prairie North Regional Health Authority	Flotten Lake Resort PDWA - Insufficient treatment	1		Operational: Does not meet minimum treatment/design requirements  Quality:
Forrest Lake Lodge [15906]	20-Jun-14 Mamawetan Churchill River Regional Health Authority	Forest Lake Lodge	1		Operational: Inadequate disinfection residual in distribution system  Quality: Total coliforms detected in drinking water system

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Foster Lake Lodge - Brunansky [17234]	15-Jun-13 Mamawetan Churchill River Regional Health Authority	Brunansky's Foster Lodge Lodge		1	Operational: Inadequate disinfection residual in distribution system  Quality: E.coli detected in drinking water system
Garden River Outfitting [1161]	21-Nov-17 Prince Albert Parkland Regional Health Authority	PDWA Issued Garden River Outfitting	1		Operational: Does not meet monitoring requirements  Quality:
Good Spirit Bible Camp - Well [13694]  NE 08-29-05 W2	15-Jul-08 Sunrise Regional Health Authority	PDWA Good Spirit Bible Camp Well - issued due to lack of water sampling.	1		Operational: Does not meet monitoring requirements  Quality:

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Greek Palace [6477]	20-Dec-16 Saskatoon Regional Health Authority	PDWA issued to Greek Palace (#6477) - Follow up by KEC	1		Operational: Undetermined source of contamination  Quality: Exceedance of MAC or drinking water standard
Hawkrock Wilderness Adventures [15003]	04-Jul-07 Mamawetan Churchill River Regional Health Authority	PDWA for Hawkrock Wilderness Adventure Ltd. due to total coliforms	1		Operational: Inadequate disinfection residual in distribution system  Quality: Total coliforms detected in drinking water system
Hepburn Lake Lodge Ltd. [15597]	21-Jun-13 Mamawetan Churchill River Regional Health Authority	Hepburn Lake Lodge Ltd.		1	Operational: Inadequate disinfection residual in distribution system  Quality: E.coli detected in drinking water system



## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
High Rock Lake Lodge [16537]	17-Jun-16  Mamawetan Churchill River Regional Health Authority	High Rock Lake Lodge TWT Ltd. (16537), PDWA, Presence of Total Coliforms	1		Operational:  Quality: Total coliforms detected in drinking water system
Hitchcock Hideaway Well [15302]	26-May-17  Heartland Regional Health Authority	PDWA for Hitchcock's Hideaway Public Accommodation	1		Operational: Does not meet minimum treatment/design requirements  Quality:
Hunter Bay Lodge [15564]	14-Jun-17  Mamawetan Churchill River Regional Health Authority	EBWO, Hunter Bay Lodge, 14jun17, 6 E.coli, >100 Total coliform		1	Operational: Inadequate disinfection residual in distribution system  Quality: E.coli detected in drinking water system

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Jan Lake Convenience Store [1100322]	02-Sep-11 Mamawetan Churchill River Regional Health Authority	Jan Lake Convenience Store		1	Operational: Inadequate disinfection residual in distribution system  Quality: E.coli detected in drinking water system
Jim and Lorna Greenway Approved Home (400429)	03-Jun-22 Regina Qu'Appelle Regional Health Authority	EBWO issued on Jim and Lorna Greenway Approved Home, N. of Earl Grey, SK, E.coli detected, May 20/22		1	Operational: Undetermined source of contamination  Quality: E.coli detected in drinking water system
Jims Meats - Water Supply [14858]  Jims Meats - food processor	27-Jan-12 Heartland Regional Health Authority	PDWA Jim's Meats - SW 28-38-24W3M in the Rural Municipality of Grass Lake # 381	1		Operational: No or inadequate disinfection at the treatment plant  Quality: Total coliforms detected in drinking water system

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Johnson River Camp [23361]	07-Jun-10 Mamawetan Churchill River Regional Health Authority	EBWO for Johnson River Camp due to E.coli		1	Operational: Inadequate disinfection residual in distribution system  Quality: E.coli detected in drinking water system
Jug Bay Sport Fishing [21119]	30-Jul-10 Mamawetan Churchill River Regional Health Authority	EBWO for Jug Bay Sport Fishing due to E.coli		1	Operational: Inadequate disinfection residual in distribution system  Quality: E.coli detected in drinking water system
K & C Meats - Well [13779]  K & C Meats [13753] - slaughter house	15-Feb-11 Sunrise Regional Health Authority	PDWA Issued for K & C Meats - Well	1		Operational: Does not meet monitoring requirements  Quality:

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Kamkota Lodge [12726]	31-May-08  Mamawetan Churchill River Regional Health Authority	EBWO for Kamkota Lodge Cabin #2 due to E.coli		1	Operational: Inadequate disinfection residual in distribution system  Quality: E.coli detected in drinking water system
Katepwa Beach Hotel (F0007331)	11-Jul-23  Sun Country Regional Health Authority	Precautionary Drinking Water Advisory issued July 11, 2023 for Katepwa Beach Hotel	1		Operational: Undetermined source of contamination  Quality: Total coliforms detected in drinking water system
KELFIELD	14-Jul-21  Heartland Regional Health Authority	PDWA issued on Kelfield Water Supply due to Iron filter problem and bypassing chlorination.	1		Operational:  Quality:

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Kennedy Hotel Well [8392]	14-Sep-23 Sun Country Regional Health Authority	Precautionary Drinking Water Advisory issued Sept. 14, 2023 for Kennedy Hotel Well located at 300 Ma	1		Operational:  Quality: Total coliforms detected in drinking water system
Kingfisher Lodge [15598]	29-May-06 Mamawetan Churchill River Regional Health Authority	EBWO Kingfisher Lodge 2 EC and 27 TC		1	Operational: Inadequate disinfection residual in distribution system  Quality: E.coli detected in drinking water system
Kings Park Speedway Well [16973]	26-May-22 Regina Qu'Appelle Regional Health Authority	EBWO Issued for Kings Park Speedway Well		1	Operational: Undetermined source of contamination  Quality: E.coli detected in drinking water system

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Klassen's Country Cut Meats	09-Dec-21  Cypress Regional Health Authority	Klassen Country Cut Meats - well - Presence of total coliform	1		Operational: Undetermined source of contamination  Quality: Total coliforms detected in drinking water system
Lady Lake Regional Park - Well [13511]  RM of Preeceville #334	15-Jun-09  Sunrise Regional Health Authority	PDWA for Lady Lake Regional Park - Well RM of Preeceville #333	1		Operational:  Quality: Total coliforms detected in drinking water system
Lake Athabasca Lodge [15383]	26-Jun-06  Mamawetan Churchill River Regional Health Authority	EBWO for Lake Athabasca Lodge due to E.coli		1	Operational: Inadequate disinfection residual in distribution system  Quality: E.coli detected in drinking water system

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Last Chance Cafe and Convenience Store Water Supply (500132)	15-Jul-21 Sunrise Regional Health Authority	Last Chance Cafe and Convenience Store Water Supply	1		Operational: Undetermined source of contamination  Quality: Total coliforms detected in drinking water system
Lawrence Bay Lodge [15216]	14-Jul-22 Mamawetan Churchill River Regional Health Authority	PDWA issued for Lawrence Bay Lodge, Reindeer Lake, Total Coliform Detected, July 14 2022	1		Operational: Treatment / distribution equipment failure or damage  Quality: Total coliforms detected in drinking water system
Lone Wolf Camps [15903]	25-Jun-07 Mamawetan Churchill River Regional Health Authority	EBWO for Lone Wolf Camps due to E.coli		1	Operational: Inadequate disinfection residual in distribution system  Quality: E.coli detected in drinking water system

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Luseland Fairgrounds Well [23333]	02-Jul-10 Heartland Regional Health Authority	PDWA - Luseland Campground	1		Operational: Undetermined source of contamination  Quality: Total coliforms detected in drinking water system
M & N Resort Distribution System [9051]	27-Jul-15 Prairie North Regional Health Authority	M & N Resort Precautionary Drinking Water Advisory	1		Operational: Does not meet minimum treatment/design requirements  Quality:
Macoun Lake Island Lodge [15212]	11-Jun-14 Mamawetan Churchill River Regional Health Authority	Macoun Lake Island Lodge	1		Operational: Inadequate disinfection residual in distribution system  Quality: Total coliforms detected in drinking water system



## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Manitou Lake Regional Park Water System [12428]	13-Jun-18  Prairie North Regional Health Authority	PDWA issued on Manitou Lake Regional Park, June 13 2018	1		Operational: Inadequate disinfection residual in distribution system  Quality: Unacceptable turbidity or particle counts in treated water
Melville Beach Community Well (26237)	04-Jul-12  Sunrise Regional Health Authority	Emergency Boil Water Order (EBWO) for Melville Beach Community Well		1	Operational:  Quality: E.coli detected in drinking water system
Milton Lake Lodge [15324]	26-Jun-06  Mamawetan Churchill River Regional Health Authority	EBWO for Milton Lake Lodge due to E.coli		1	Operational: Inadequate disinfection residual in distribution system  Quality: E.coli detected in drinking water system

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Minor Bay Lodge [15010]	22-Jun-10 Mamawetan Churchill River Regional Health Authority	PDWA for Minor Bay Lodge & Outpost Ltd - Spencer Lake Outpost due to total coliforms	1		Operational: Inadequate disinfection residual in distribution system  Quality: Total coliforms detected in drinking water system
Misaw Lake Lodge [15135]	25-Jun-16 Mamawetan Churchill River Regional Health Authority	Misaw Lake Lodge, EBWO, 9 TC/4 E.coli		1	Operational: Inadequate disinfection residual in distribution system  Quality: E.coli detected in drinking water system
Missi Lake Lodge [15261]	12-Jun-15 Mamawetan Churchill River Regional Health Authority	Missi Lake Lodge	1		Operational: Inadequate disinfection residual in distribution system  Quality: Total coliforms detected in drinking water system

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Morning Lake Outfitters [16118]	14-Jun-07 Mamawetan Churchill River Regional Health Authority	EBWO for Morning Lake Outfitters due to E.coli		1	Operational: Inadequate disinfection residual in distribution system  Quality: E.coli detected in drinking water system
Nemeiben Lake Campground [15937]	18-May-18 Mamawetan Churchill River Regional Health Authority	PDWA Nemeiben Lake Campground (Lac La Ronge) 18May18	1		Operational: Does not meet minimum treatment/design requirements  Quality:
Nemeibien Lake Canoe & Bible Camp [21043]	04-Jul-13 Mamawetan Churchill River Regional Health Authority	Nemeibien Lake Canoe & Bible Camp	1		Operational: Inadequate disinfection residual in distribution system  Quality: Total coliforms detected in drinking water system

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Norseman Outfitters [17572]	21-Apr-11 Prince Albert Parkland Regional Health Authority	Norseman Outfitting EBWO due to E.coli		1	Operational: Does not meet reporting requirements  Quality: E.coli detected in drinking water system
Northern Lights Lodge - Public Water Supply [12244]	25-Jun-21 Mamawetan Churchill River Regional Health Authority	PDWA Northern Lights Lodge 25June2021	1		Operational: Does not meet minimum treatment/design requirements  Quality: Total coliforms detected in drinking water system
Northern Reflection Lodge [15265]	22-Jun-10 Mamawetan Churchill River Regional Health Authority	PDWA for Northern Reflection Lodge due to total coliforms	1		Operational: Inadequate disinfection residual in distribution system  Quality: Total coliforms detected in drinking water system

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Nut Point Campground [15816]	18-May-18 Mamawetan Churchill River Regional Health Authority	PDWA Nut Point Campground (Lac La Ronge) 18May18	1		Operational: Does not meet minimum treatment/design requirements  Quality:
Osin Community Well [13767]	06-Oct-22 Sunrise Regional Health Authority	EBWO for OSIN Community Well	1		Operational: Contamination during construction, repair or operation  Quality: Total coliforms detected in drinking water system
Paull River Wilderness Camp [12523]	17-Jun-09 Mamawetan Churchill River Regional Health Authority	EBWO for Paull River Wilderness Camps due to E.coli		1	Operational: Inadequate disinfection residual in distribution system  Quality: E.coli detected in drinking water system

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Phil Foster Wilderness Fishing [15819]	25-Jun-07 Mamawetan Churchill River Regional Health Authority	PDWA for Phil Foster Wilderness Fishing due to total coliforms	1		Operational: Inadequate disinfection residual in distribution system  Quality: Total coliforms detected in drinking water system
Pickerel Bay Cabins Ltd. [15268]	11-Jun-10 Mamawetan Churchill River Regional Health Authority	EBWO for Pickerel Bay Cabins Ltd. due to E.coli		1	Operational: Inadequate disinfection residual in distribution system  Quality: E.coli detected in drinking water system
Pilots Lodge [17110]	01-Jul-07 Mamawetan Churchill River Regional Health Authority	EBWO for Pilot's Lodge due to E.coli		1	Operational: Inadequate disinfection residual in distribution system  Quality: E.coli detected in drinking water system

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Pine Point Lodge & Outpost - Athapapuskow Lake [14162]	08-Jun-07 Mamawetan Churchill River Regional Health Authority	PDWA for Pine Point Lodge & Outpost due to total coliforms	1		Operational: Inadequate disinfection residual in distribution system  Quality: Total coliforms detected in drinking water system
Pine Ridge Resort Well [F0034188]	25-May-23 Kelsey Trail Regional Health Authority	PDWA issued on Pine Ridge Resort Well	1		Operational: Does not meet minimum treatment/design requirements  Quality:
Pipestone Lake Lodge [12506]	25-Jun-07 Mamawetan Churchill River Regional Health Authority	PDWA for Pipestone Lake Fishing Lodge Inc. due to total coliforms	1		Operational: Inadequate disinfection residual in distribution system  Quality: Total coliforms detected in drinking water system

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Pointer Lake Lodge [12548]	04-Jun-10 Mamawetan Churchill River Regional Health Authority	PDWA for Pointer Lake Lodge due to total coliforms	1		Operational: Inadequate disinfection residual in distribution system  Quality: Total coliforms detected in drinking water system
Prairie Shores Camp	28-Jun-18 Heartland Regional Health Authority	Prairie Shores EBWO located in RM 255		1	Operational: No or inadequate disinfection at the treatment plant  Quality: E.coli detected in drinking water system
Prairie Lake Regional Park Water Supply [23306]	28-Jun-12 Heartland Regional Health Authority	EBWO - Prairie Lake Regional Park Water Supply issued due to the presence of E coli		1	Operational: Does not meet minimum treatment/design requirements  Quality: E.coli detected in drinking water system



## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Readlyn Water Co-operative [16221]	30-Jul-09  Five Hills Regional Health Authority	Readlyn Water Co-op PDWA	1		Operational: Does not meet minimum treatment/design requirements  Quality: Suspected contamination
RM 32 - Well 4 (Kenler) [8777]	11-Jul-24  Sun Country Regional Health Authority	Emergency Boil Water Order issued to municipal well located at RM 32 NE 11-6-32 W1		1	Operational:  Quality: E.coli detected in drinking water system
Rolling Hills Water Lines Co-operative [16878]	01-Aug-17  Regina Qu'Appelle Regional Health Authority	PDWA- Rolling Hills Water Lines Co-operative	1		Operational: No certified or adequately trained operator as required  Quality: Suspected contamination

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Rolling Hills Water Lines Co-operative [16878]	09-Jan-23  Regina Qu'Appelle Regional Health Authority	PDWA - Rolling Hills Water Lines Co-operative	1		Operational: Inadequate disinfection residual in distribution system  Quality: Suspected contamination
Rural Municipality of Buchanan No. 304 - Well (SE 23-32-4-W2) [13621]	25-Mar-11  Sunrise Regional Health Authority	PDWA for R.M. of Buchanan Well No. 4 (SE-23-32-4 - Est.#13621) replaces EBWO of May 13, 2010	1		Operational:  Quality: Total coliforms detected in drinking water system
Rural Municipality of Buchanan No. 304 - Well No. 1(NW 22-30-6 W2M) [13623]	08-May-08  Sunrise Regional Health Authority	PDWA Issued - RM of Buchanan - Well No. 1	1		Operational:  Quality: Total coliforms detected in drinking water system

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Rural Municipality of Buchanan No. 304- Well No. 1 (NW 22-30-6 W2M)	04-Aug-22  Cypress Regional Health Authority	EBWO issued to Rural Municipality of Buchanan No. 304- Well No. 1 (NW 22-30-6 W2M)		1	Operational: Undetermined source of contamination  Quality: E.coli detected in drinking water system
Rural Municipality of Sliding Hills No. 273 - Well No. 1 [13625]	24-Oct-16  Sunrise Regional Health Authority	PDWA - Rural Municipality of Sliding Hills No. 273 - Well No. 1 [13625]	1		Operational: Undetermined source of contamination  Quality: Total coliforms detected in drinking water system
Sask. Landing Provincial Park Bison Hollow/Prairie Meadow Campground Public Water Supply (700393)	19-May-21  Heartland Regional Health Authority	PDWA issued on Bison Hollow/Prairie Meadow Campground Seasonal Startup May 19, 2021	1		Operational: Start up of waterworks  Quality:

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Scott Lake Lodge [15144]	13-Jul-10  Mamawetan Churchill River Regional Health Authority	EBWO for Scott Lake Lodge Ltd. due to E. coli		1	Operational: Inadequate disinfection residual in distribution system  Quality: E.coli detected in drinking water system
Seager Wheeler Farm [6909]  Seager Wheeler Farm - well [6909]	29-Jul-16  Saskatoon Regional Health Authority	PDWA Issued to Seager Wheeler Farm (#006909) - Follow up by DL July 29, 2016	1		Operational: Undetermined source of contamination  Quality: Total coliforms detected in drinking water system
Shell River Campground [130]	28-Sep-17  Prince Albert Parkland Regional Health Authority	EBWO Issued Spruce River Campground		1	Operational: Does not meet monitoring requirements  Quality: E.coli detected in drinking water system

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Silence of the North - PW [1100168]  Silence of the North [1100168]	18-Jul-16  Mamawetan Churchill River Regional Health Authority	Silence of the North, PDWA, 8 TC	1		Operational: Inadequate disinfection residual in distribution system  Quality: Total coliforms detected in drinking water system
Slim's Cabins - Kamuchawie Lake [13978]	20-Jun-11  Mamawetan Churchill River Regional Health Authority	PDWA Issued at Slim's Cabins Ltd. - Kamuchawie Lake - due to detection of total coliforms	1		Operational: Inadequate disinfection residual in distribution system  Quality: Total coliforms detected in drinking water system
South Bay Outfitters [15672]	05-Jun-14  Mamawetan Churchill River Regional Health Authority	South Bay Outfitters		1	Operational: Inadequate disinfection residual in distribution system  Quality: E.coli detected in drinking water system

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Sportsman's Lodge Ltd. [15272]	27-Jun-17  Mamawetan Churchill River Regional Health Authority	EBWO, Sportsman's Lodge Ltd., 27jun17, 1 e.coli, 1 total coliform		1	Operational: Inadequate disinfection residual in distribution system  Quality: E.coli detected in drinking water system
Spring Bay Lodge [15127]	29-Jun-13  Mamawetan Churchill River Regional Health Authority	Spring Bay Lodge		1	Operational: Inadequate disinfection residual in distribution system  Quality: E.coli detected in drinking water system
Stockman's Lodge [15346]	28-Jun-17  Mamawetan Churchill River Regional Health Authority	PDWA, Stockman's Lodge, 28Jun2017, 16 total coliforms	1		Operational: Inadequate disinfection residual in distribution system  Quality: Total coliforms detected in drinking water system

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Sturgis & District Regional Park - Lady Lake Site #012914	07-Jun-24  Sunrise Regional Health Authority	PDWA issued to Sturgis & District Regional Park - Lady Lake Site (#012914) - total coliform presence	1		Operational: Undetermined source of contamination  Quality: Total coliforms detected in drinking water system
Sturgis & District Regional Park - Lady Lake Site - Well	13-Jun-23  Sunrise Regional Health Authority	PDWA issued to Sturgis & District Regional Park-Lady Lake Site-013511	1		Operational: Undetermined source of contamination  Quality: Total coliforms detected in drinking water system
Suffern Lake Regional Park Cabins Water Supply 2015 (700037)	14-May-19  Heartland Regional Health Authority	PDWA Suffern Lake Regional Park Water Cabin Water Supply	1		Operational: Start up of waterworks  Quality:

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Suffern Lake Water Supply Clubhouse - Well #2 [15557]	14-May-19 Heartland Regional Health Authority	PDWA Suffern Lake Regional Park Clubhouse and Campground Water Supply Issued due to Seasonal Startup	1		Operational: Start up of waterworks  Quality:
Tawaw Cabins Water Distribution System (29283)	25-Jun-20 Prairie North Regional Health Authority	TAWAW Cabins Water Distribution system - High Turbidity	1		Operational: Treatment / distribution equipment failure or damage  Quality: Unacceptable turbidity or particle counts in treated water
The Harvest Moon Café - Well (25956)	17-Nov-17 Cypress Regional Health Authority	The Harvest Moon Cafe - Well		1	Operational: Does not meet minimum treatment/design requirements  Quality: E.coli detected in drinking water system



## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
The New Canoe Lake West Resort 1987 [16087]	02-Aug-19 Mamawetan Churchill River Regional Health Authority	The New Canoe Lake West Resort 1987, EBWO, E. coli detected in water system		1	Operational: Does not meet minimum treatment/design requirements  Quality: E.coli detected in drinking water system
Thunder Mountain Outfitting [21930]	06-Jun-09 Mamawetan Churchill River Regional Health Authority	EBWO for Thunder Mountain Outfitting due to E.coli		1	Operational: Inadequate disinfection residual in distribution system  Quality: E.coli detected in drinking water system
Tinker's Camp (27816)	21-Jul-14 Mamawetan Churchill River Regional Health Authority	Tinker's Camp		1	Operational: Inadequate disinfection residual in distribution system  Quality: Total coliforms detected in drinking water system

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Top of the Rock Adventures [23552]	17-Jun-10 Mamawetan Churchill River Regional Health Authority	PDWA for Top of the Rock Adventures due to total coliforms	1		Operational: Inadequate disinfection residual in distribution system  Quality: Total coliforms detected in drinking water system
True North Lodge [17361]	20-Jun-08 Mamawetan Churchill River Regional Health Authority	EBWO issued for True North Lodge [17361]		1	Operational:  Quality: E.coli detected in drinking water system
Twin Lake Fly-in [15704]	08-Jun-12 Mamawetan Churchill River Regional Health Authority	Twin Lake Fly-in Ltd.	1		Operational: Inadequate disinfection residual in distribution system  Quality: Total coliforms detected in drinking water system

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Unity Golf Club Well (27367)	08-May-17 Heartland Regional Health Authority	PDWA Issued to Unity Golf Club Well Due to Overgrown Bacteriological Result	1		Operational:  Quality: Total coliforms detected in drinking water system
Valley View Tea Room/Ancient Echos Well [17918]	08-Jul-22 Heartland Regional Health Authority	PDWA issued on Valley View Tea Room Well, Herschel, High Level of Total Coliform, July 08, 2022	1		Operational:  Quality: Total coliforms detected in drinking water system
Vermilion Lake Outfitters [23585]	08-Jun-12 Mamawetan Churchill River Regional Health Authority	Vermillion Lake Lodge	1		Operational: Inadequate disinfection residual in distribution system  Quality: Total coliforms detected in drinking water system

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Village of Punnichy - Punnichy Golf Club (25122)	25-Aug-22  Regina Qu'Appelle Regional Health Authority	PDWA issued on Village of Punnichy - Punnichy Golf Club Punnichy SK, August 25, 2022 Total Coliforms	1		Operational: Does not meet minimum treatment/design requirements  Quality: Total coliforms detected in drinking water system
VJ's Fishing Lodge Ltd. [12608]	08-Jun-07  Mamawetan Churchill River Regional Health Authority	PDWA for V.J. Fishing Camp due to total coliforms	1		Operational: Inadequate disinfection residual in distribution system  Quality: Total coliforms detected in drinking water system
Whitewood Auction Services Limited	12-Jun-18  Regina Qu'Appelle Regional Health Authority	PDWA - Whitewood Auction Services Limited	1		Operational: Does not meet monitoring requirements  Quality: Suspected contamination

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Wolf Willow Winery Water System (700240)	18-Sep-23 Heartland Regional Health Authority	PDWA Issued on Wolf Willow Winery Water system, NE 36-30-08 W3 Due to Presence of total coliforms	1		Operational: Undetermined source of contamination  Quality: Total coliforms detected in drinking water system
Wollaston Lake Lodge [15711]	19-Aug-22 Mamawetan Churchill River Regional Health Authority	PDWA Issued for Wollaston Lake Lodge, Wollaston Lake, Total Coliform Detected, Aug 19, 2022	1		Operational: Inadequate disinfection residual in distribution system  Quality: Total coliforms detected in drinking water system
Wood Mountain Regional Park Well - Showers [11263]	08-Jun-11 Five Hills Regional Health Authority	PDWA Issued for Wood Mountain Regional Park Shower Well	1		Operational: Inadequate disinfection residual in distribution system  Quality: Unacceptable turbidity or particle counts in treated water

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Wood Mountain Regional Park Well - Showers [11263]	08-Jun-11 Five Hills Regional Health Authority	PDWA Issued - Wood Mtn RP Showers Well	1		Operational:  Quality: Unacceptable turbidity or particle counts in treated water
Wymark Skating Rink - Water Supply [21425]  Wymark Skating Rink	23-Jan-20 Cypress Regional Health Authority	Wymark Skating Rink PDWA	1		Operational: Does not meet monitoring requirements  Quality:
Wynyard and District Regional Park [7613]	25-Jun-20 Saskatoon Regional Health Authority	Wynyard District Regional Park turbidity excess of 2 ntu	1		Operational: Damaged or inadequately maintained cistern or holding tank  Quality: Unacceptable turbidity or particle counts in treated water

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
York Lake Slow Pitch - Well [13322]	20-Jun-24 Sunrise Regional Health Authority	PDWA Issued for York Lake Slow Pitch Well, Elevated Turbidity and Manganese, June 20, 2024	1		Operational: Does not meet minimum treatment/design requirements  Quality: Unacceptable turbidity or particle counts in treated water
	07-Mar-20 Prince Albert Parkland Regional Health Authority	PDWA-Victoria Hospital, Prince Albert	1		Operational: Undetermined source of contamination  Quality: Unacceptable turbidity or particle counts in treated water
	06-Aug-21 Mamawetan Churchill River Regional Health Authority	Bayview Lodge PDWA	1		Operational: Does not meet minimum treatment/design requirements  Quality: Total coliforms detected in drinking water system

## Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Thu, 25 Jul 2024 09:16:03 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
	11-Jul-24  Sunrise Regional Health Authority	Camp Whitesand		1	Operational: Contamination during construction, repair or operation  Quality: E.coli detected in drinking water system
	07-Jun-24  Sunrise Regional Health Authority	PDWA issued to Newbury Snacks (#F0095935) due to unapproved construction	1		Operational: Does not meet monitoring requirements  Quality:
<b>Totals:</b>			<b>96</b>	<b>47</b>	
<b>Advisories/Orders Currently in Effect:</b>			<b>143</b>		